

## *New Projects Submitted to DDW During the Past 12 Months*

*Sorted by Date Received*

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
11/2/2015	10237	SUTHERLAND LDS CHURCH	14041	(COMPLETED) Exception to rule request for storage capacity requirement R309-510-8	Chartier
11/2/2015	10238	WEBER BASIN WCD - CENTRAL	29023	12th Street Water Line Replacement (4700 W and Little Mountain) - 24-in PVC	Harry
11/2/2015	10240	WILLARD CITY WATER SYSTEM	02024	R309-500-6(3)(b) Plan Submittal Waiver Eligibility	Lunstad
10/30/2015	10234	NIBLEY CITY WATER	03001	After-the-fact review, chlorinators at Nelson Well WS006 and 4000 S Main Well WS004 (TP00? & TP00?)	Lunstad
10/28/2015	10231	LILA CANYON MINE	08048	Lila Canyon Underground Water Mine (WS001)	Ariotti
10/28/2015	10232	LILA CANYON MINE	08048	New PWS drinking water facilities including TP001....	Ariotti
10/28/2015	10233	LILA CANYON MINE	08048	NTNC PWS Capacity Development Evaluation	Dev
10/26/2015	10235	TAYLOR-WEST WEBER WID	29019	R309-500-6(3)(a) Plan Submittal Waiver Eligibility: 5/1/2013 Master Plan (IFFP)	Brenchley
10/26/2015	10236	TAYLOR-WEST WEBER WID	29019	3500 West Phase 2 Water Lines - 2,800 ft of 14-in PVC	Brenchley
10/23/2015	10228	HOOPER WATER IMPROVEMENT DIS	29006	(COMPLETED) 4500 West from 700 S to 300 S; 2,000 ft of 12-in water line: 500-6(3)(b) waiver	Brenchley
10/22/2015	10227	HEBER CITY WATER SYSTEM	26006	(COMPLETED) Millstream RV Park Phase 2: 1,465 ft of 8-in water line; R309-500-6(3)9b) Waiver	Brenchley
10/22/2015	10230	WASATCH LDS CAMP	15042	Pioneer Trail Subd./Dutch Hollow Water Co. Water Tank Repair - recoat interior	North
10/21/2015	10226	SOUTH SALT LAKE CITY WATER SYS	18032	2015 700 E Well (WS012) chemical treatment	Brenchley
10/19/2015	10224	KAYSVILLE CITY WATER SYSTEM	06006	Parkwood Phase 1 - 38 lots, 2,300 feet of 8-in water lines	Dev
10/15/2015	10223	SUMMIT WATER DISTRIBUTION COM	22059	(COMPLETED) Frostwood F6 Townhomes - 887 ft of 8-in PVC, 9 laterals, 3 air/vacs, 4 hydrants	Brenchley

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
10/13/2015	10219	ENOCH CITY WATER SYSTEM	11004	600 East to 6000 North 8-in and 12-in water line to serve youth home	Wright
10/13/2015	10222	LEHI CITY	25015	Mitchell Hollow Interconnect emergency connection with American Fork	Brenchley
10/12/2015	10216	SUMMIT WATER DISTRIBUTION COM	22059	(COMPLETED) Exceptions for overflow connecting to storm drain (ST006, ST002, St003, ST010) and for overflow discharging without	North
10/12/2015	10220	JORDANELLE SSD	26086	(COMPLETED) Victory Ranch Plat T R309-500-6(3)(b) waiver request	Brenchley
10/12/2015	10221	SALEM CITY	25001	Tablet Chlorinator (TP006) at the Storage Reservoir Well (WS003)	Brenchley
10/8/2015	10210	PAROWAN CITY WATER SYSTEM	11010	Race Track Well (WS006) - reactivate well and install RP assembly	Wright
10/8/2015	10214	BONA VISTA WATER DISTRICT	29004	[COMPLETE] Knight Center 8" Water Line , Far West City , R309-500-6(3)(b) Plan Sub. Waiver	Harry
10/8/2015	10215	BONA VISTA WATER DISTRICT	29004	[COMPLETE] Edgewood 4 Subdivision Water Lines, Far West City, R309-500-6(3)(b) waiver request	Harry
10/8/2015	10217	WASHINGTON COUNTY WCD - SAND	27073	Sand Hollow Well #28 (WS016)	Wright
10/8/2015	10218	WASHINGTON COUNTY WCD - SAND	27073	Sand Hollow Well #29 (WS017)	Wright
10/6/2015	10204	NORTH OGDEN CITY	29010	R309-500-6(3)(b) Plan Submittal Waiver Eligibility Request	Harry
10/6/2015	10207	TAYLOR-WEST WEBER WID	29019	(COMPLETED) Meadow Green Estates - West Haven: R309-500-6(3)(b) waiver request	Brenchley
10/5/2015	10213	POWDER MOUNTAIN WSID	29028	Sundown Lodge water line replacement and extension.	Hart
10/2/2015	10209	ZIONS PEAK CAMP	22140	Wellhouse, iron removal, water lines, 8,000 gal. tank (ST002), and hydrants	North
10/1/2015	10205	GREEN RIVER CITY	08005	CIB Funded. Water lines in Tarmac, Sharon and Pirate Streets and between Kiings Lane and 1000 North.	Ariotti
10/1/2015	10206	SALINA CITY WATER SYSTEM	21014	CIB Funded-Tank (ST00?), Well (WS00?), water lines.	Chartier
9/30/2015	10239	HIDDEN HOLLOW WATER COMPANY	15041	2015 WTTC letter & follow up on the conditions	Brenchley

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
9/29/2015	10198	BOX ELDER COUNTY GENERAL	02000	Technical Assistance - fire flow for small systems in Box Elder Co.	Brenchley
9/29/2015	10208	UTAH STATE HOSPITAL	25092	Slate Canyon Spring (WS001) - exception to R309-515-7(7)(e) spring fencing	Kobzeff
9/28/2015	10199	BONA VISTA WATER DISTRICT	29004	[COMPLETED] Post Storage Units 8-in water line and fire hydrant: R309-500-6(3)(b) waiver	Harry
9/28/2015	10200	BONA VISTA WATER DISTRICT	29004	[COMPLETED] Sierra RV Site, Marriott-Slaterville City, water line; (3)(b) waiver request & exception to R309-550-7	Harry
9/24/2015	10191	HILDALE - COLORADO CITY	27006	Jan's Canyon Spring (WS001) trans. Line repair - 6000 ft of 2-in HDPE	Wright
9/24/2015	10196	MORONI CITY	20013	Master Plan SRF# 3S213P	Cobleigh
9/23/2015	10194	LAYTON CITY WATER SYSTEM	06018	(COMPLETED) Greyhawk Townhome Apts - 1304 ft of 8-in water line - Waiver b request	Brenchley
9/23/2015	10195	TAYLORSVILLE-BENNION ID	18021	Taylorville East Well (WS002) rehab and exception to R309-500-6(6)(a)	Dev
9/23/2015	10197	EAST CANYON RESORT	15033	Technical Assistance - source capacity evaluation	North
9/23/2015	10201	MENDON CITY	03011	(COMPLETED) Engineering Study - Groundwater Evaluation	Hall
9/23/2015	10203	LONG VALLEY ESTATES	13050	8,400 ft of water line (from Alton pipeline), booster pump, hydrants, relocate tank	Wright
9/21/2015	10190	PARK CITY WATER SYSTEM	22011	(COMPLETED) Iron Canyon Tank (ST010) - exception to R309-545-14 for tank hatch height	North
9/18/2015	10187	SANTA CLARA CITY	27016	(COMPLETED) The Sycamores - 3,200 ft. of 8-in water lines: 3b Plan Submittal Waiver	Wright
9/18/2015	10188	SANTA CLARA CITY	27016	(COMPLETED) The Hills at Santa Clara Phase 2B - 900 ft. of 8-in water line: 3b Plan Sub. Waiver	Wright
9/17/2015	10179	MOUNTAIN REGIONAL WATER SSD	22137	(COMPLETED) Black Hawk Booster Station (PF006) - exception for cooling system water	North
9/17/2015	10181	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Shadybrook Phase 2A (9 lots) water lines - 3a plan submittal waiver request	Hall
9/17/2015	10182	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Wild Horse Ranch Phase 1 (23 lots) water lines - 3a plan submittal waiver	Hall

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
9/17/2015	10183	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) SR138 Water Line Crossing at Clark Dr. - R309-500-6(3)(a) Plan Submittal Waiver	Hall
9/17/2015	10184	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Village Boulevard Water Lines (2000 ft) - R309-500-6(3)(a) Plan Submittal Waiver	Hall
9/17/2015	10192	TREMONTON CITY	02011	(COMPLETED) R309-500-6(3)(b) Waiver Eligibility Request	Brenchley
9/17/2015	10193	WELLSVILLE CITY WATER SYSTEM	03022	(COMPLETED) R309-500-6(3)(b) Plan Submittal Waiver Eligibility Request	Lunstad
9/15/2015	10185	SANTA CLARA CITY	27016	(COMPLETED) Snow Canyon Estates 2,600 ft of 8-in and 12-in water line: 3b Plan Sub. Waiver	Wright
9/15/2015	10186	SANTA CLARA CITY	27016	(COMPLETED) Bella Sol Phase 5 - 1,200 ft of 8-in water line: 3b Plan Submittal Waiver	Wright
9/15/2015	10189	BONA VISTA WATER DISTRICT	29004	[COMPLETED] Colby Creek Estates Phase 2 - 14 lots in West Haven - 3b Plan Submittal Waiver	Harry
9/12/2015	10175	KANE COUNTY WCD - JOHNSON CA	13038	FSRF #3F165 - Tank (ST003) and 1 mile of transmission line	Wright
9/11/2015	10174	TWIN CREEKS SSD	26080	Red Ledges Phase 2K - 8" and 14" water lines, 81 connections, 23 fire hydrants	Cobleigh
9/11/2015	10177	WEST JORDAN CITY WATER SYSTE	18020	(COMPLETED) PRV installation at 8600 South 6120 West plan submittal waiver request	Lunstad
9/10/2015	10168	RICHFIELD CITY	21013	Replace gas chlorine system with chlorine tablet system	Chartier
9/10/2015	10169	WENDOVER CITY WATER SYSTEM	23008	SRF# 3S207P Master Plan	Kobzeff
9/10/2015	10171	WEBER BASIN WCD - CENTRAL	29023	(WS006) District Well No. 2 lining & rehabilitation (previously inactive well since late 80's or early 90's)	Harry
9/10/2015	10212	POWDER MOUNTAIN WSID	29028	Summit at Powder Mountain Phase 1D revised	Hart
9/9/2015	10202	PANGUITCH LAKE CHAPEL	09092	Exception to Storage Sizing Requirements of R309-510-8	Wright
9/4/2015	10166	PLYMOUTH TOWN WATER SYSTEM	02013	SRF# 3S217 500,000 tank and distribution line	Kobzeff
9/4/2015	10170	HOOPER WATER IMPROVEMENT DIS	29006	5500 S and 4800 S water line - 4 miles of 18" DI replacing PVC & exception to R309-550-7	Harry

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
9/4/2015	10172	STANSBURY PARK IMPROVEMENT D	23003	Well No. 1 (WS001) tablet chlorinator (TP001) - Change from sodium hypochlorite to tablet	Hall
9/3/2015	9932	HUNTSVILLE TOWN WATER SYSTEM	29007	Water Line connection to Monastery (Abby of the Holy Trinity WS#29039, which is a now a non-public system)	Hall
9/3/2015	10165	HERRIMAN CITY MUNICIPAL WATER	18157	(COMPLETED) Ridge Subd. - 3,500 ft 8-in PVC, 180 ft 12-in DI, 53 conn. - R309-500-6(3)(b) waiver	Lunstad
9/2/2015	10176	WINDY RIDGE PIPELINE & RES OPE	26062	Replacement of 600-feet of 8" C-900 class 200 DR14 PVC water lines (from 2' to 6' deep) and associated valves, hydrants, and	Lunstad
8/31/2015	10162	BONA VISTA WATER DISTRICT	29004	[COMPLETE] 750 West WL replacement - 12-in PVC with railroad crossing - (3)(b) waiver	Harry
8/31/2015	10163	JORDAN VALLEY WCD	18027	Temporary Chlorination Connection for Riverton Wholesale Connection	Lunstad
8/31/2015	10173	HANKSVILLE TOWN WATER SYSTEM	28003	SRF# 3S199P Master Plan	Hall
8/27/2015	10167	WEBER BASIN JOB CORPS	06008	PWS evaluation & follow up on the WTTC letter conditions	North
8/26/2015	10160	HERRIMAN CITY MUNICIPAL WATER	18157	(COMPLETED) Eligibility Waiver Request for Waiver A and B, Hydraulic Modeling, and PE designation over system and hydraulic	Lunstad
8/26/2015	10164	ST GEORGE CITY WATER SYSTEM	27015	Standard Installation Drawings for R309-500-6(3)(b) waiver eligibility; PWS & hydraulic modeling PE designations	Wright
8/25/2015	10158	YOUNG LIVING FARMS	12020	new distribution system (DS001)	Chartier
8/24/2015	10157	TONY GROVE LAKE CAMPGROUND-	03051	Spring redevelopment (WS001) to eliminate surface water influence	Kobzeff
8/21/2015	10154	STANSBURY PARK IMPROVEMENT D	23003	3MG tank (ST003) and appurtenances	Hall
8/21/2015	10155	NIBLEY CITY WATER	03001	640 West Well (WS007) - new well	Kobzeff
8/21/2015	10156	UINTAH HIGHLANDS IMPROVEMENT	29021	Reactivate 2559 S Combe Well (WS003) - technical assistance	Harry
8/20/2015	10153	DESERET FEEDLOT	25044	Phase 2 Improvements - water line upgrade from 6-in to 8-in; 2 connections	North
8/20/2015	10159	YOUNG LIVING FARMS	12020	(COMPLETED) Temp water hauling to serve the new outdoor arena bathrooms for draft horse event Sept 2015	Chartier

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
8/20/2015	10178	HENRIEVILLE TOWN WATER SYSTE	09006	Source Development Study SRF #3S189P	Hall
8/19/2015	10152	OGDEN VALLEY COMMUNITY CHUR	29122	New Water System - Church Well (WS001), dist. line, and pressure tank	Harry
8/17/2015	10150	SKOOTS CREEK SUBDIVISION	09053	WTTC letter follow up	Wright
8/17/2015	10151	ERDA ACRES WATER CO.	23053	Clover Blossom Subdivision - 8-in and 10-in water lines, 29 connections, 6 hydrant	Hall
8/17/2015	10161	MOUNTAIN REGIONAL WATER SSD	22137	Bison Bluffs Well, Well 15-C (WS024)	Cobleigh
8/14/2015	10149	JORDAN VALLEY WCD	18027	615 East Pipeline Replacement - R309-550-7 water/sewer separation exception	Lunstad
8/13/2015	10147	HURRICANE CITY	27007	Storage tank for desanding (OT001) and pump station (PF010) and Chlorinator (TP004)	Wright
8/13/2015	10148	HOME VALLEY WATER COMPANY	27035	(COMPLETED) 8,000 gallon fiberglass water storage tank (ST002)	Wright
8/13/2015	10180	WOLF CREEK WATER AND SEWER I	29013	The Ridge Phase 2 - two buildings, 4 units each, 8 ERCs	Hart
8/12/2015	10145	BONA VISTA WATER DISTRICT	29004	[COMPLETED] S-Curve Subd. In Plain City - 76 lots, 8-in. lines - Waiver per R309-500-6(3)(b)	Harry
8/12/2015	10146	BONA VISTA WATER DISTRICT	29004	[COMPLETED] Edgewood West Subd in Plain City - 30 lots, 8-in lines; R309-500-6(3)(b) waiver	Harry
8/11/2015	10142	HOUWELINGS TOMATOES	12028	New PWS capacity development review per R309-800	Dev
8/11/2015	10143	CEDAR CITY WATERWORKS	11002	South Tank (ST010) interior recoating	Wright
8/7/2015	10140	TAYLORSVILLE-BENNION ID	18021	(COMPLETED) State Lab Module #2 Water Line (1,120 ft of 8-in) - R309-500-6(3)(b) waiver	Lunstad
8/7/2015	10141	BRIAN HEAD TOWN WATER SYSTEM	11001	Mammoth tank water line - 4,800 feet of 6-in PVC and 8-in HDPE	Wright
8/5/2015	10139	JORDANELLE SSD	26086	(COMPLETED) Victory Ranch Plat J2 (Broken Stick Dr aka Constellation Ct) R309-500-6(3)(b) waiver	North
8/4/2015	10138	THE NOTCH	22064	Notch Well (WS003)	Onysko

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
8/3/2015	10133	WASHINGTON COUNTY WCD - COTT	27071	Toquer Well #1 (WS005) near Anderson Junction	Wright
8/3/2015	10134	LINCOLN BEACH	25129	(COMPLETED) County Well (WS001) - MPA sample	North
8/3/2015	10135	GOSHEN TOWN WATER SYSTEM	25013	Ercanbrack Spring (WS001) - E. coli in spring	North
7/31/2015	10070	ROOSEVELT CITY WATER SYSTEM	07004	400 East waterline, 300 North waterline, 400 North waterline and 300 East waterline	Hall
7/30/2015	10128	CROSS HOLLOW HILLS SUBDIVISIO	11055	Consecutive connection (WS004) from Central Iron Co. WCD (#11085), valve vault and SCADA	Wright
7/30/2015	10130	HEBER CITY WATER SYSTEM	26006	[COMPLETED] Power Industrial Park (2,800 ft of 8-in water line) R309-500-6(3)(b) waiver	Onysko
7/30/2015	10131	HEBER CITY WATER SYSTEM	26006	(COMPLETED) Ranch Landing Plat B, 1300' 8" WL, Waiver 6(3)(b)	Onysko
7/30/2015	10136	TOOELE ARMY DEPOT	23022	ATF-North Area Water Mains: 32,471 ft of 8-in, 5,198 ft of 10-in, 5,158 ft of 16-in	Hall
7/30/2015	10137	TOOELE ARMY DEPOT	23022	ATF-North Area Tanks: ST006 (adj to ST004), ST007 (replaces ST001), ST008 (replaces ST002)	Hall
7/29/2015	10129	MARBLE HILLS SUBDIVISION	02058	Technical Assistance - Randy Moulding Connection, Inadquate Pressure, Exception Request	Hart
7/29/2015	10132	PARK CITY WATER SYSTEM	22011	(COMPLETED)High West Distillery 4-in sewer lateral -exception to R309-550-7 water/sewer separation	Cobleigh
7/28/2015	10123	TAYLORSVILLE-BENNION ID	18021	(COMPLETED) Legacy 5400 South (6 conn), 933 ft of 8-in PVC: R309-500-6(3)(b) plan sub waiver	Lunstad
7/28/2015	10124	FARMINGTON CITY WATER SYSTEM	06004	(COMPLETED) Avenues at the Station Phase 2, 1100 ft of 8-in PVC: R309-500-6(3)(b) waiver	Dev
7/28/2015	10125	FARMINGTON CITY WATER SYSTEM	06004	[COMPLETED] Red Barn Recovery Center, 515 ft 12-in, 320 ft 8-in PVC: R309-500-6(3)(b) waiver	Harry
7/28/2015	10126	JARVIE HISTORICAL SITE	05032	Exception to R309-545-13, tank (ST001) overflow requirement	Hacking
7/27/2015	9929	TROPIC TOWN WATER SYSTEM	09008	CIB Spring Creek (WS003) and Dr Goode Spring (used only for irrigation) redevelopment	Wright
7/27/2015	10120	TWIN CREEKS SSD	26080	(COMPLETED) Red Ledges Phase 2J, 8-in water lines: R309-500-6(3)(b) plan submittal waiver	Cobleigh

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
7/27/2015	10121	KAYSVILLE CITY WATER SYSTEM	06006	Sunset Equestrian Estates Sub. Phase 14C (19 lots) - 1,300 ft of 8-in water line	Dev
7/27/2015	10122	GUNNISON CITY	20004	Sorensen Well (WS007) - USDA-funded	Chartier
7/25/2015	10127	BIG COTTONWOOD PINE TREE WAT	18139	Pinetree Spring (WS001) - MPA Sample	Lunstad
7/23/2015	10119	LAYTON CITY WATER SYSTEM	06018	(COMPLETED)Evergreen Farms Phase 3 (48 lots) 10-in water lines: R309-500-6(3)(b) waiver req	Dev
7/22/2015	10116	BONA VISTA WATER DISTRICT	29004	[COMPLETE] Hales Estates Subdivision water lines (62 lots) - waiver per R309-500-6(3)(b)	Harry
7/22/2015	10117	OREM CITY WATER SYSTEM	25020	(COMPLETED) 150 West and 1000 South water line replacement - exception to R309-550-7 for water/sewer separation	North
7/22/2015	10211	POWDER MOUNTAIN WSID	29028	Summit at Powder Mountain - Phase 1E/1F/1G Distribution System	Hart
7/21/2015	10114	HOUWELINGS TOMATOES	12028	WTTC Letter - New PWS Capacity Development Evaluation	Chartier
7/21/2015	10115	WASHINGTON COUNTY WCD - KOLO	27097	equipping Whispering Pines Well No. 1 (WS004; formerly WS001 in System #27095) & installing new Whispering Pines hypochlorinator	Wright
7/16/2015	10110	PROVO CITY	25006	Transmission Lines/PRV station for west-side tanks (proposed ST012 and ST013)	North
7/16/2015	10111	TAYLOR-WEST WEBER WID	29019	3MG tank and 800-ft each of 10-inch, 12-inch and 16-inch distribution line (FSRF# 3F234)	Peterson
7/16/2015	10112	TAYLOR-WEST WEBER WID	29019	Pumpstation (3 pumps in parallel on VFD's) (FSRF# 3F234)	Peterson
7/16/2015	10113	KEARNS IMPROVEMENT DISTRICT	18011	6200 South 24-in and 18-in water lines and fire hydrants & Exception to R309-550-7	Kobzeff
7/15/2015	10108	COTTONWOOD MUTUAL	15013	(COMPLETED) Increase pumping capacity for Rose Hill Well No. 3 (WS009)	Dev
7/15/2015	10109	SANDY CITY WATER SYSTEM	18028	Ksel Drive Water Line - 160 feet of 8-in. DI pipe, two valves, one PRV	Lunstad
7/14/2015	10107	CROYDON PIPELINE CORPORATION	15001	After-the-fact plan review of 800 feet of water line	Harry
7/12/2015	10104	BENNION CREEK CAMPGROUND	25122	Filtration System (TP001) - 6 filters (bag and cartridge); exception to R309-550-6 for NSF 61 certification for filter housing	North

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
7/12/2015	10118	DUGWAY WARD	23065	Reverse Osmosis Treatment Unit (TP002)	North
7/10/2015	10105	JORDAN VALLEY WCD	18027	ST001, ST002, ST009, ST014, and ST017 Tank Repair and Repainting	Lunstad
7/9/2015	9928	WELLINGTON CITY	04011	CIB Tank (ST001) refurbishment and SCADA	Ariotti
7/8/2015	10101	CROSS HOLLOW HILLS SUBDIVISIO	11055	335K Tank (ST002) interior recoating and repair	Wright
7/8/2015	10103	WASATCH MOUNTAIN ST PARK	26010	After-the-Fact WS005 Intertie w/PRV, to Sys. #26011	Onysko
7/7/2015	10102	JOSEPH TOWN	21009	(COMPLETED) Replace gas chlorination system with tablet feeder chlorination system.	Chartier
7/6/2015	10099	ASHLEY VALLEY WATER AND SEWE	24013	2015 Water Sys. Improvements: 11,000 feet of 8-in PVC and 25 fire hydrants	Hacking
7/1/2015	10098	COVE FORT RV PARK	14061	(COMPLETED) Request for exception to R309-540-6 and R309-510-8 for storage requirement	Chartier
6/30/2015	10100	LAYTON CITY WATER SYSTEM	06018	Willow Ridge Subdivision Phase 1 - plan submittal waiver per R309-500-6(3)(b)	Harry
6/26/2015	10086	MANTI CITY	20005	(COMPLETED) Big Spring (WS008) - MPA sampling	Chartier
6/26/2015	10087	MANTI CITY	20005	Sister Spring (WS004) - MPA sampling	Chartier
6/26/2015	10088	CLARKSTON TOWN WATER SYSTEM	03004	(COMPLETED) North Fork Spring (WS001) - MPA sampling	Cobleigh
6/26/2015	10089	CLARKSTON TOWN WATER SYSTEM	03004	Big Birch Spring (WS002) - MPA sampling	Cobleigh
6/26/2015	10090	NEWTON TOWN WATER SYSTEM	03013	(COMPLETED) North Fork Spring (WS001) - MPA sampling	Cobleigh
6/26/2015	10091	NEWTON TOWN WATER SYSTEM	03013	Big Birch Spring (WS002) - MPA sampling	Cobleigh
6/26/2015	10092	TRENTON TOWN WATER SYSTEM	03021	(COMPLETED) North Fork Spring (WS001) - MPA sampling	Cobleigh
6/26/2015	10093	TRENTON TOWN WATER SYSTEM	03021	Big Birch Spring (WS002) - MPA sampling	Cobleigh

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
6/26/2015	10094	CAMP TIMBER LANE	07032	Timberlane Spring (WS001) - MPA sampling after spring redevelopment	North
6/26/2015	10095	ASPEN CREST GIRLS CAMP	26012	Stewart Ranch Spring (WS001) - MPA sampling	Onysko
6/25/2015	10040	WEBER RIVER REC CAMP	22148	After-the-fact PWS engineering evaluation	North
6/25/2015	10083	PROVO CITY	25006	Slate Canyon Heights pump station	North
6/25/2015	10084	PROVO CITY	25006	Slate Canyon Heights - request for plan submittal waiver	North
6/25/2015	10085	COALVILLE CITY WATER SYSTEM	22002	Water Treatment Plant (TP002)	North
6/23/2015	10081	ANDERSON COVE CAMPGROUND	29033	Westside and mainline water line replacement - 750 ft of 1-in, 3,900 ft of 2-in, and 1,900 ft of 3-in HDPE	Harry
6/22/2015	10073	TANNERS FLAT CAMPGROUND	18070	(Complete) Reactivate Tanner's Chlorinator (TP001) and exception to NSF/ANSI 61 standard	Harry
6/22/2015	10074	TANNERS FLAT CAMPGROUND	18070	(COMPLETE) Tanner's Spring (WS001) MPA sampling	North
6/22/2015	10077	BALLARD WATER IMPROVEMENT DI	24001	Ballard Convenience Store water line extension - 500 feet of 8-in PVC	Hacking
6/22/2015	10078	DUTCH JOHN TOWN WATER SYSTE	05001	0.5 MG concrete tank, replace 1,300 feet of 6 inch pipe SRF#3S216	Kobzeff
6/22/2015	10082	ASPEN MEADOWS	22138	Camp Spring (WS001) redevelopment	Cobleigh
6/22/2015	10096	PAYSON CITY WATER SYSTEM	25021	Technical Assistance: 7 low psi, pre-TP001 connections	Onysko
6/18/2015	10106	HOME VALLEY WATER COMPANY	27035	(COMPLETED) WS002 - new well to replace Well #1 (WS001)	Wright
6/17/2015	10071	EAST CANYON RESORT	15033	(COMPLETED) After-the-fact engineering review of pre-filter and UV treatment system (TP001)	Lunstad
6/17/2015	10072	OGDEN CITY WATER SYSTEM	29011	Ogden Business Exchange Water Transmission Line - 3,200-ft of 12-in pipe and 1,500-ft of 8-in fire hydrant laterals	Lunstad
6/16/2015	10069	PRICE MUNICIPAL CORPORATION	04007	CIB project - 400 South water main	Ariotti

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
6/15/2015	10061	CEDAR HIGHLANDS SUBDIVISION	11042	WS002 and WS003 Springs - reactivation and after-the-fact review	Wright
6/12/2015	10065	ASPEN GROVE CAMPGROUND	26065	Aspen Grove Well (WS001) deficiency - well casing in vault	Onysko
6/12/2015	10066	SOLDIER CREEK RECREATION COM	26067	Soldier Creek Well (WS001) Casing Stick-Up IPS Deficiency	Onysko
6/11/2015	10064	LAYTON CITY WATER SYSTEM	06018	Shop Well (WS009) rehabilitation and exception to R309-515-6(6)(a)	Dev
6/11/2015	10067	THE OTHER END	26050	Other End Replacement Well (WS002)	Onysko
6/10/2015	10063	SALT LAKE CITY WATER SYSTEM	18026	(COMPLETED) Bishop Place Sewer Exception Request	Lunstad
6/10/2015	10068	MAESER IMPROVEMENT DISTRICT	24004	Hidden Cove Subdivision - R309-550-7 exception to water/sewer separation	Hacking
6/9/2015	10062	BOUNTIFUL PEAK CAMPGROUND	06025	(SUSPENDED) Technical Assistance - Chlorinator (TP001) deficiency	Dev
6/1/2015	10059	ELK RIDGE TOWN	25031	Reactivate Dugway Well (WS002, formerly Well #2)	North
6/1/2015	10060	WHITE HILLS SUBDIVISION	25119	3F226 Interior re-coating of 0.5 MG steel tank. Painting of 0.5 MG and 0.2 MG steel tanks. And 8,240 feet of 10-inch PVC installation.	Kobzeff
6/1/2015	10080	POWDER MOUNTAIN WSID	29028	(COMPLETED) Connection of the Hidden Lake Tank to existing system	Hart
5/29/2015	10053	POWDER MOUNTAIN WSID	29028	Spring #1 (Pizzel Spring) WS001 - MPA sampling	Hart
5/29/2015	10056	CENTRAL UTAH WCD - UTAH VALLE	25112	Geneva Complex Gas-Cl (TP005) and Eagle Mtn Pump Station Hypo-Cl (TP006)	North
5/29/2015	10057	WHITE CITY WID	18019	(COMPLETED) Exception Request for Minimum Separation Requirements along Onyx Lane	Lunstad
5/29/2015	10058	HELAMAN HOLLOW RECREATION CA	04057	Hypochlorinator and iron removal (TP001) upgrade - add. Tank, pre-chlorination, flush-to-waste line	Ariotti
5/29/2015	10097	CENTRAL UTAH WCD - UTAH VALLE	25112	(COMPLETED) Provo River WTP (TP001) - Exception Request to increase filtration rate and increase capacity from 80 to 100 MGD	Lunstad
5/28/2015	10055	GARLAND CITY WATER SYSTEM	02009	1400 West 8-in Water Line project - plan submittal waiver per R309-500-6(3)(a)	Kobzeff

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
5/27/2015	10052	DUCHESNE CO WCD	07069	Phase 2 of the Victory Pipeline project	Kobzeff
5/26/2015	10054	OGDEN CITY WATER SYSTEM	29011	Ogden Business Exchange Water Transmission Line - 6,050-ft of 24-in pipe	Lunstad
5/20/2015	10044	PARK CITY MOUNTAIN RESORT	22094	New ST006 (50K), 6-Inch WLto Snow Hut	Onysko
5/20/2015	10046	HEBER CITY WATER SYSTEM	26006	[COMPLETED] Cottages at Valley Stn. Phase 3, Waiver 6(3)(b)	Onysko
5/20/2015	10047	HEBER CITY WATER SYSTEM	26006	[COMPLETED] Swift Creek Phase 3, 8" WL, 960 E & Old Mill Dr., Waiver 6(3)(b)	Onysko
5/20/2015	10048	HEBER CITY WATER SYSTEM	26006	[COMPLETED] Valley Heights Plat A, 12"/8" WL, 1050 N & Mill Rd., Waiver 6(3)(b);	Onysko
5/19/2015	10043	WASHINGTON COUNTY GENERAL	27000	Harmony Canyon Well	Wright
5/18/2015	10049	TAYLOR-WEST WEBER WID	29019	Construct approximately 1,200 L.F. each of 12-inch and 16-inch PVC pipelines through the West Haven apartments property. Connect to	Peterson
5/15/2015	10041	MOAB GIANTS	10043	Well No. 2 (WS003), distribution piping; Exception to storage req't	Ariotti
5/14/2015	10035	CENTRAL UTAH WCD - ASHLEY VALL	24038	Ashley Spring Intake (WS003) - reclassify from intake to UDI spring	North
5/14/2015	10036	ASHLEY VALLEY WATER AND SEWE	24013	Ashley Spring Intake (WS001) - reclassify from intake to UDI spring	North
5/13/2015	10039	WATSON SHELTER WATER SYSTEM	18125	(COMPLETED) new 12,000-gal fiberglass Watson Spring Tank (ST002) and flow meter - replacing existing tank (ST001)	Lunstad
5/11/2015	10032	ST GEORGE CITY WATER SYSTEM	27015	Exception for Spring Fencing WS001, WS002, WS004 - WS008	Hall
5/11/2015	10033	SPANISH FORK CITY	25003	Cold Springs - Lower (WS017) MPA sample result	North
5/11/2015	10037	DIAMOND HILLS ASSOCIATION	26073	Diamond Hills Well (WS003)	Hall
5/11/2015	10042	ASPEN RANCH	28037	Water system reactivation - engineering review	Chartier
5/8/2015	10034	TAYLOR-WEST WEBER WID	29019	Quail Meadows Estates (47 lots) - plan submittal waiver per R309-500-6(3)(b)	Harry

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
5/8/2015	10051	FAIRVIEW CITY WATER SYSTEM	20012	3S198P Master Plan	Kobzeff
5/7/2015	10029	CENTRAL IRON COUNTY WCD	11085	Eagle Valley Ranches Well Chlorinator (TP003)	Wright
5/7/2015	10030	HURRICANE CITY	27007	Sand Hollow Pump Station (PF009) modifications	Wright
5/6/2015	10028	LAYTON CITY WATER SYSTEM	06018	Adams Farms Subdivision plan submittal waiver request per R309-500-6(3)(b)	Dev
5/6/2015	10031	WASHINGTON COUNTY GENERAL	27000	Holmstead Ranch Water System - courtesy review	Wright
5/6/2015	10079	WATERPRO INC	18006	(COMPLETED) Palomino Point Phase 2 - exception to R309-550-7 water/sewer separation	Dev
5/5/2015	10027	SUMMIT WATER DISTRIBUTION COM	22059	Willow Draw Road Water Line - 1,888 ft of 14-in and 150 ft of 20-in HDPE, 5 hydrants, 1 air-vac valve	Harry
5/5/2015	10050	BEAR RIVER WCD-BEAVER DAM	02002	Lower Beaver Springs (WS002) - MPA Result	Hart
5/4/2015	10075	UKON WATER COMPANY	02014	Bear Hollow Ranch Subdivision (19 lots plus boat and guest houses)	Hart
5/4/2015	10076	UKON WATER COMPANY	02014	Bear Hollow Ranch connection to Ukon Water Company	Hart
4/30/2015	10021	BRICKERHAVEN SUBDIVISION	25023	(COMPLETED) Technical assistance to resolve significant physical deficiencies including storage deficiency	North
4/30/2015	10022	ST GEORGE CITY WATER SYSTEM	27015	(COMPLETED) Arsenic Blending Plan - City Creek Well (WS015) with Mountain Springs (SS953) to T-bone Tank (ST013)	Wright
4/30/2015	10045	RAINBOW MEADOW RANCHOS	11038	Redevelop Zelda Spring (WS003) install 570-ft of 3-in transmission line, and 750 ft of 2-inch conveyance line, filling station, and 1,000	Wright
4/29/2015	10024	CENTRAL VALLEY TOWN	21006	Exception to R309-515-6(12)(d)(iv) - check valve on discharge piping for Mecham Well (WS004)	Chartier
4/28/2015	10038	GRAND WATER AND SEWER AGENC	10023	(COMPLETED) 2015 waterline replacement - SRF Project 3S215	Hall
4/27/2015	10023	TAYLORSVILLE-BENNION ID	18021	Wirthlin Exploratory Well (WS029)	Dev
4/24/2015	10019	NIBLEY CITY WATER	03001	Technical Assistance - UDI Spring Number One (WS001)	North

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
4/23/2015	10020	CORINNE CITY	02005	Radium Treatment (TP00?) Pilot Study for Cutler Well (WS003)	Harry
4/22/2015	10018	TWIN CREEKS SSD	26080	Red Ledges Phase 2G - 8-in DI water line - R309-500-6(3)(b) waiver request	Cobleigh
4/20/2015	10012	NORTH VALLEY RANCHES SUB	27086	Engineering review of new public water system	Wright
4/20/2015	10013	NORTH VALLEY RANCHES SUB	27086	(ON HOLD - WELL NOT IN USE) - Well #2 After the fact review	Wright
4/20/2015	10014	TAYLOR-WEST WEBER WID	29019	Exception request (well house drain to daylight)	Peterson
4/20/2015	10015	NORTH VALLEY RANCHES SUB	27086	New PWS capacity development evaluation	Dev
4/20/2015	10016	SALINA CITY WATER SYSTEM	21014	Master Plan SRF# 3S205P	Kobzeff
4/16/2015	10011	OLD PINERY RECREATION AREA	12027	Request to Haul Water - Summer of 2015	Chartier
4/16/2015	10025	WEBER RIVER REC CAMP	22148	Request to Haul Water - Summer 2015	Hall
4/15/2015	10008	COALVILLE CITY WATER SYSTEM	22002	(COMPLETED)Master Plan SRF# 3S186P	Cobleigh
4/15/2015	10009	GLEN CANYON SSD #1	13003	Master Plan SRF# 3S200P	Kobzeff
4/13/2015	10006	MURRAY CITY WATER SYSTEM	18024	(COMPLETED) R309-500-6(3)(b) waiver eligibility req., PWS PE designation, and PWS const. standards	Lunstad
4/10/2015	10003	CHRISTMAS MEADOWS CABINS	22112	Technical Assistance - storage volume deficiency	Cobleigh
4/9/2015	10001	BUCKS GRILL HOUSE	10018	Exception request to min. storage sizing requirements of R309-510-8 and technical assistance - storage deficiency evaluation	Ariotti
4/9/2015	10002	LIBERTY PIPELINE COMPANY	29008	Technical Assistance - resolve significant physical deficiency and verify treatment facilities	Hart
4/8/2015	9997	PARK CITY WATER SYSTEM	22011	McPolin Farm PRV Vault - create North Thaynes and McPolin pressure zones	Cobleigh
4/8/2015	10000	ST GEORGE CITY WATER SYSTEM	27015	Cliffs Subdivision at Entrada - PRV Station	Wright

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
4/8/2015	10007	BEAVER HIGH ADVENTURE BASE	01039	6-inch Beaver Mountain Well with pitless adapter (WS002)	Wright
4/7/2015	9993	PINE MEADOW MUTUAL WATER	22079	Replace booster pump station at 500k gallon tank 3F170	Kobzeff
4/7/2015	9994	HYDE PARK CITY WATER SYSTEM	03007	(COMPLETED) Technical assistance - resolve the leaky tank deficiency (ST00?) & guidance on CAP	Kobzeff
4/7/2015	9996	COMMUNITY WATER COMPANY	22012	After-the-fact plan approval and operating permits for Lookout Lodge pump facility (PF003) and water tank (ST003)	Cobleigh
4/7/2015	9998	TWIN CREEKS SSD	26080	Red Ledges Phase 2H (8-in. water line extension) - R309-500-6(3)(b) waiver request	North
4/7/2015	9999	WILLOW CREEK WATER CO	02062	(COMPLETED) Technical Assistance- Capacity Calculations	Kobzeff
4/2/2015	9987	WALLSBURG TOWN WATER SYSTE	26009	(COMPLETED) Main street water line replacement CDBG funded	Kobzeff
4/2/2015	10005	JUAB COUNTY GENERAL	12000	New 6-inch well at Houwelling Tomatoes Mona facility	Chartier
4/2/2015	10010	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Hypochlorite liquid systems for Wells #1 WS001 and #3 WS003 (TP001, TP003); Tablet chlorinator for Well #2 WS002	Hall
4/1/2015	9986	TICABOO UTILITY IMPROVEMENT DI	09022	SRF# 3S206 Well #1 pump and pumphouse, solar panels for well #1 and well #2	Wright
4/1/2015	9989	MAPLETON CITY	25018	South Mapleton Water Line Proj. Phase 1 - Hwy 89 from 800 to 4000 South	Hall
4/1/2015	10004	MAPLETON CITY	25018	South Mapleton Water Line Proj. Phase 2 - fill line from Crowd Canyon well (WS008) to Crowd Canyon tank	Hall
3/30/2015	9984	SALT LAKE CITY WATER SYSTEM	18026	Upper Boundary Spring (WS006) reconstruction and control vault replacement at tanks	Dev
3/30/2015	9985	CHRIS TRADING POST	29048	(COMPLETED) Request for exception to R309-515-6(13)(b) drain to daylight for well house serving both wells (WS001 and WS002)	North
3/27/2015	9982	SOUTH DAVIS WATER DISTRICT	06009	Replace PRV, install PSV, 10 in. steel sleeve with 6 in. HDPE insert, direct tie-in to Weber Basin	Dev
3/27/2015	9983	BRIGHTON MEADOWS LDS GIRLS C	22136	PHASE 1 and 2: Tollgate Camps - booster sta., CI2, tank, 4 PRVs, water lines, meters, and hose bibs.	Cobleigh
3/27/2015	9988	CANNONVILLE TOWN WATER SYSTE	09003	Master Plan SRF#3S187P	Cobleigh

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
3/25/2015	9979	BIRDSEYE BRANCH	25110	Follow up on 2010 W TTC letter and approvals of system and source	North
3/25/2015	9980	STOCKTON TOWN WATER SYSTEM	23010	Anti-scalant addition to pre-filters (TP007) and exceptions to R309-525-11(6)(a)(iv)(A)&(C) and (10)	Hall
3/25/2015	9990	ATK PROMONTORY PLANT	02032	[COMPLETE] X1 Tank (ST005) and X2 Tank (ST006) interior repair and repainting	Harry
3/24/2015	9981	OLYMPUS ACADEMY	27088	New PWS capacity development evaluation (business plan review)	Dev
3/23/2015	9975	TAYLOR-WEST WEBER WID	29019	900 South well (FSRF# 3F234)	Peterson
3/23/2015	9976	LA VERKIN CITY WATER SYSTEM	27009	Sunset View Estates (53 Lots) - 8" PVC water lines and booster pump system (PF002)	Wright
3/23/2015	9977	YOUNG LIVING FARMS	12020	(COMPLETED) Temp water hauling for Visitor's Center and caretaker's quarters	Chartier
3/19/2015	9972	WENDOVER CITY WATER SYSTEM	23008	Bonneville Club - 1,240 ft. 8-in. water line, 34 condos, 8 RV pads, and clubhouse	Hall
3/19/2015	9973	CENTRAL IRON COUNTY WCD	11085	(COMPLETED) SRF funded Master Plan 3S203P	Cobleigh
3/18/2015	9933	KRISHNA TEMPLE	25178	PWS after-the-fact engineering evaluation	North
3/18/2015	9934	KRISHNA TEMPLE	25178	Krishna Temple Well (WS001)	North
3/18/2015	9971	COBBLE CREEK CAMP	29089	Cobble Creek Spring (WS001) rehab, two 5,000 gal water tanks, and chlorination	Harry
3/18/2015	9978	LINDON CITY	25016	(COMPLETED) Request for source reduction	North
3/17/2015	9953	WASHAKIE RENEWABLE ENERGY	02080	Washakie Well (WS001) - New Source Review	Harry
3/17/2015	9970	WASHAKIE RENEWABLE ENERGY	02080	new PWS capacity assessment plan	Dev
3/16/2015	9969	UINTAH HIGHLANDS IMPROVEMENT	29021	200,000 gal. concrete tank (ST003) , 835 ft 10-in. DI, and chlorination building	Harry
3/10/2015	9968	CAMPS BEN LOMOND-SHAWNEE	29062	(COMPLETED) TP001 filter upgrade, flush to waste valve for startup, pH indicator, temp. sensor, and Cl2 analyzer	North

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
3/9/2015	9966	BEAR RIVER WCD-TREMONTON	02066	Bear River Canal Crossing	Hart
3/9/2015	9967	UKON WATER COMPANY	02014	Bear River Canal Crossing	Hart
3/5/2015	10017	ROCKVILLE PIPELINE CO	27014	Master Plan (FSRF# 3F220P)	Peterson
3/4/2015	9958	MURRAY CITY WATER SYSTEM	18024	(COMPLETED) Separation Exception Request for 500 West sewer line replacement (between 4500 South and 4800 South)	Harry
3/4/2015	9959	HILL AIR FORCE BASE	06024	(COMPLETE) Plan review waiver b eligibility request.	Johnson
3/4/2015	9960	LAKESIDE RANGE	02060	(COMPLETE) Plan review waiver b eligibility request	Johnson
3/4/2015	9961	LITTLE MOUNTAIN TEST FACILITY	29118	(COMPLETE) Plan review waiver b eligibility request	Johnson
3/4/2015	9962	CARTER CREEK WATER SYSTEM	22120	(COMPLETE) Plan review waiver b eligibility request	Johnson
3/2/2015	9954	NORTH OGDEN CITY	29010	Lakeview Heights well house replacement, includes replacing pipelines and chlorine system.	Johnson
3/2/2015	9955	CENTRAL UTAH WCD - DUCHESNE V	07050	(COMPLETE) Duchesne Plant - switch primary coagulants, from aluminum sulfate to ferric chlorine	Hart
3/2/2015	9956	DESERET - OASIS SSD	14051	(COMPLETED) 4500 South Pipeline - replacing 4,140 ft of 6-in with 8-in PVC pipe	Chartier
3/2/2015	9957	MONTICELLO CITY	19004	Iron/Manganese removal (TP002) treating Hideout Well WS008 water	Ariotti
3/2/2015	9963	MIA SHALOM RECREATION CAMP	20039	7 Springs redevelopment Phase I & exception to fencing req't around collection area (WS003-WS009)	Chartier
3/2/2015	9964	MIA SHALOM RECREATION CAMP	20039	7 Springs redevelopment Phase II	Chartier
3/2/2015	9965	MIA SHALOM RECREATION CAMP	20039	7 Springs redevelopment Phase III	Chartier
2/25/2015	10144	ERDA ACRES WATER CO.	23053	(COMPLETED) Technical Assistance - updating inventory of water facilities	Hall
2/24/2015	9880	ERDA ACRES WATER CO.	23053	(COMPLETED) England Estates - Water lines	Hall

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
2/20/2015	9951	HILL AIR FORCE BASE	06024	[Cancelled] Fluoride and phosphate feed switch from dry to liquid (TP002, 003, 005, and 009)	Harry
2/19/2015	9948	EDEN WATERWORKS SYSTEM	29005	(COMPLETE) Sandhill Crane Cluster Subd. (7 lots): technical assistance-feasibility letter	Hart
2/19/2015	9949	TAYLOR-WEST WEBER WID	29019	(COMPLETE) Blue Acres Subdivision (9 lots): technical assistance - feasibility letter	Hart
2/19/2015	9950	SOUTH SALT LAKE CITY WATER SYS	18032	(COMPLETED) Davis Well (WS003) Acid Treatment	Hall
2/18/2015	9947	HERRIMAN CITY MUNICIPAL WATER	18157	11800 South Water Line - 7,500 feet of 16-in. DIP from JVVCD to new 5 MG tank	Lunstad
2/17/2015	9819	HANNA WATER & SEWER IMPROVE	07062	CIB project - 750,000 gallon tank	Kobzeff
2/17/2015	9946	IVINS	27008	Taviawk Booster Pump Station (PF001) Upgrade - intall three 25-hp pumps	Wright
2/10/2015	9944	HIGHLAND CITY	25014	Exception to R309-550-7 water/sewer separation Dry Creek and River Bend Rds	Kobzeff
2/9/2015	9938	CEDAR CITY WATERWORKS	11002	(COMPLETED) 400 North Water Line Replacement - replace 10-in water line beneath I-15	Wright
2/9/2015	9942	CORINNE CITY	02005	Batty-Cutler Chlorinator (TP001) - replace tablet chlorinator with gas	Johnson
2/9/2015	9974	ANGELL SPRINGS SSD	27074	(COMPLETED) Exception to minimum pressure requirements of R309-105-9 (Bull Dog Subd. - 3 lots), Use of individual home booster	Wright
2/6/2015	9937	FOUNTAIN GREEN	20003	Exception to R309-515-7(7)(e) spring collection area fencing req. for WS001	Chartier
2/6/2015	9945	HEBER CITY WATER SYSTEM	26006	(COMPLETED) Broadhead Estates, Ph. 2, 8'/12" WL, Not Waiver 6(3)(a)	Onysko
2/5/2015	9930	EAST DUCHESNE CULINARY WID	07051	CIB Transmission pipeline	Hacking
2/5/2015	9931	ORANGEVILLE	08008	CIB waterline replacement	Ariotti
2/4/2015	9926	MOUNTAIN REGIONAL WATER SSD	22137	Promontory Ph. 2 - Mid. Valley 1 MG tank and pump sta.; Ph. 1 - Summit pump sta.	Cobleigh
2/4/2015	9927	SCOFIELD ESTATES WATER	04056	Convert an abandoned gas well to drinking water well (WS005) and well house	Ariotti

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
2/4/2015	9935	STERICYCLE TOOELE COUNTY FACI	23092	New Water System	Hall
2/4/2015	9936	STERICYCLE TOOELE COUNTY FACI	23092	Water Hauling	Hall
2/3/2015	9939	WEST ERDA IMPROVEMENT DISTRIC	23001	(COMPLETED) SRF# 3S197P Regional Water Study	Hall
2/2/2015	9922	KEARNS IMPROVEMENT DISTRICT	18011	5 MG Tank (ST011) and 30-inch Water Line	Dev
2/2/2015	9923	CAMPS BEN LOMOND-SHAWNEE	29062	(COMPLETED) Chlorinator (sodium hypochlorite) in Cole Canyon Pump Vault (PF001)	Johnson
2/2/2015	9924	JORDANELLE SSD	26086	Victory Ranch, Lots 206-211, 8-In. WL, R309-500-6(3)(b) waiver	Onysko
2/1/2015	9952	WASHAKIE RENEWABLE ENERGY	02080	New PWS evaluation	Johnson
1/30/2015	9917	WEBER BASIN-SUMMIT	22147	(COMPLETED) Interconnection - Mountain Reg. (22137) wholesale water supply to Summit Water (22059) via pipe installed by Weber	Cobleigh
1/30/2015	9918	SPRINGVILLE CITY	25005	(COMPLETED) Lower Spring Creek Tanks (ST004 and ST005)-emergency overflow modifications	North
1/30/2015	9941	SUMMIT WATER DISTRIBUTION COM	22059	(COMPLETED) Interconnection - Mountain Reg. (22137) wholesale water supply to Summit Water (22059) via pipe installed by Weber	Cobleigh
1/30/2015	9943	MOUNTAIN REGIONAL WATER SSD	22137	(COMPLETED) Interconnection - Mountain Reg. (22137) wholesale water supply to Summit Water (22059) via pipe installed by Weber	Cobleigh
1/29/2015	9912	OREM CITY WATER SYSTEM	25020	(COMPLETED) After-the-fact PA and OP for 7 clorination stations (TP003, TP004, TP005, TP006, TP007, TP011, TP012)	North
1/29/2015	9914	GRANTSVILLE CITY	23002	(COMPLETED) West Bench water line (4300 ft) and 1000 gpm West Bench pump station (PF002)	Hall
1/29/2015	9916	PINECLIFF CAMP	22078	(COMPLETED) Tablet Chlorinator (TP001) treating WS001 Pine Cliff Well	North
1/29/2015	9925	MONA TOWN WATER SYSTEM	12002	(COMPLETED) 12-inch transmission line from storage tanks to north end of water system	Chartier
1/28/2015	9913	DRAPER CITY WATER SYSTEM	18133	Minuteman Drive - 660 ft of 24-in DI and new PRV vault	Kobzeff
1/28/2015	9915	HIDEOUT TOWN WATER SYSTEM	26100	Soaring Hawk Subdivision, Phases 1 and 2: Plan Sub. Waiver per R309-500-6(3b)	Cobleigh

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
1/23/2015	9909	SYRACUSE CITY WATER SYSTEM	06012	1000 West Water Line proj. - reconnect 35 services from 4-in to 10-in main (STAG)	Johnson
1/22/2015	9908	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) after the fact review of Reserve Subdivision Phase 2 (13 lots)	Hall
1/22/2015	9910	OREM CITY WATER SYSTEM	25020	(COMPLETED) new Canyon Springs 50,000 gal. tank (ST007), relocation of pump station (PF003) and gas chlorinator (TP002)	North
1/21/2015	9902	SARATOGA SPRINGS CITY	25138	Market Street and Riverside Drive waterline and Exception request for minimum separation at Pioneer Crossing	North
1/21/2015	9903	BRYCE CANYON NATIONAL PARK	09045	Re-coat Hills Small Tank 302,000 G (ST002) and Hills Large Tank 1 MG (ST001)	Wright
1/21/2015	9904	CENTRAL UTAH WCD - UTAH VALLE	25112	(COMPLETED) Waiver Request for minimum separation crossing at Pioneer crossing.	North
1/21/2015	9906	LAYTON CITY WATER SYSTEM	06018	(COMPLETED) Hillfield Well (WS001) - well rehab & exception to R309-515-6(6)(a)	Dev
1/21/2015	9907	CLINTON CITY WATER SYSTEM	06003	[COMPLETED] 2 chlorinators - WBWCD chlorine booster treating WS001 (TP001) & Clinton well chlorinator treating WS002 (TP002)	Harry
1/20/2015	9901	MURRAY CITY WATER SYSTEM	18024	(WITHDRAWN) 4500 South waterline replacement between 600 west and 300 west-Request for Plan Review Waiver	Hall
1/16/2015	9911	CENTRAL IRON COUNTY WCD	11085	(COMPLETED) after the fact review of Northridge Well Tablet Chlorinator (TP005) - should have been submitted with File #9827	Wright
1/15/2015	9919	MOUNTAIN REGIONAL WATER SSD	22137	(COMPLETED)R309-500-6(3)(a) Plan Submittal Waiver Eligibility Request	Cobleigh
1/15/2015	9920	MOUNTAIN REGIONAL WATER SSD	22137	(COMPLETED)R309-500-6(3)(b) Plan Submittal Waiver Eligibility Request	Cobleigh
1/15/2015	9921	MOUNTAIN REGIONAL WATER SSD	22137	(COMPLETED)R309-511-4(1)(a)(iii) Hydraulic Analysis PE Designation	Cobleigh
1/13/2015	9899	TAYLOR-WEST WEBER WID	29019	waterline replacement along 2700 West (between 3300 South and 3600 South) and transmission line to new tank; 4,350 ft of 12-inch	Johnson
1/13/2015	9905	PACIFICORP HUNTINGTON PLANT	08034	Water Supply Well (WS002?)	Ariotti
1/12/2015	9898	SARATOGA SPRINGS CITY	25138	(COMPLETED) Well #2 & Well #3 gas chlorinators (TP002, TP003) to replace liquid chlorination	Kobzeff
1/8/2015	9897	LIBERTY PIPELINE COMPANY	29008	8-inch well, 1,000-feet deep, at Camp Lomondi (WS012)	Harry

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
1/7/2015	9895	WEBER BASIN WCD - CENTRAL	29023	East Layton Trans. Line Replacement - 8,700 ft of 36-in steel and HDPE after-the-Fact review; exceptions to R307-550-6(7)(a) and	Harry
1/5/2015	9816	WEBER COUNTY MEMORIAL PARK-E	29078	East Spring chlorinator (TP001), booster pump (PF001), 8000-gal tank (ST003), and 4-in piping (NEEDS OPERATING PERMIT)	Johnson
1/5/2015	9894	BOULDER FARMSTEAD WATER CO	09002	FSRF #3F225 SR-12 pipeline extension, 5 new PRV stations, Lower Boulder Road pipeline, Redevelop Jepsen Spring (WS001), and	Wright
1/2/2015	9893	SANTAQUIN CITY	25002	Plan Submittal Waiver Eligibility Request per R309-500-6(3)(a) and (3)(b)	North
12/30/2014	9892	TAYLORSVILLE-BENNION ID	18021	[Completed] Exception to R309-550-7 minimum separation requirements for 4100 South sewer relief project	Harry
12/23/2014	9896	POWDER MOUNTAIN WSID	29028	(COMPLETED) Inadequate source and potential storage capacity	North
12/22/2014	9891	LAYTON CITY WATER SYSTEM	06018	(COMPLETED) Villas at Harmony Place PRUD 4, 5, 6 (12 ERCs) plan waiver per R309-500-6(3)(b)	Harry
12/19/2014	9890	MOSIDA HANDCART TREK	25176	(COMPLETED) Hauled water from Helper (WS002), 15,000-gal tank (ST001), booster pump (PF001), tank fill station, hydrants, and	North
12/16/2014	9889	TAYLOR-WEST WEBER WID	29019	Blue Acres Subd. Phase 4 - R309-500-6(3)(b) waiver req. - 1,350 ft of 10-in PVC, 3 valves, 2 fire hydrants, 1 blowoff	Harry
12/9/2014	9886	VA MEDICAL CENTER SLC	18173	(COMPLETED) Capacity Development review for new Community PWS	Dev
12/9/2014	9887	PARK CITY WATER SYSTEM	22011	IMC Hospital water line relocation (Quinn's Junction) - 1,100 ft of 10-in DI	Cobleigh
12/9/2014	9888	EPHRAIM CITY	20011	(COMPLETED) Relocate Canyon Road Chlorinator (TP002) to new building	Chartier
12/8/2014	9878	CHRIS TRADING POST	29048	(COMPLETED) Exception to R309-510-8, storage sizing requirement	North
12/8/2014	9879	SALT LAKE CITY WATER SYSTEM	18026	(ON HOLD) 4549 South Zarahemla - low press. Zone service connection - technical assistance	Lunstad
12/8/2014	9881	TAYLOR-WEST WEBER WID	29019	Della Lucia Ground (34 lots) water lines - waiver req. per R309-500-6(3)(b) - 2130 ft of 10-in, 600 ft of 8-in, 6 valves, 6 fire hyd. (NEEDS	Johnson
12/8/2014	9882	ERDA ACRES WATER CO.	23053	(COMPLETED) Field of Dreams Phase 2 (19 lots) 8-in water line	Hall
12/8/2014	9883	ERDA ACRES WATER CO.	23053	(COMPLETED) Exemption from hydraulic modeling rpt. Submittal per R309-511-4(1)(a)(iii)	Hall

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
12/8/2014	9884	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Northport Phase 2 - plan submittal waiver per R309-500-6(3)(a)	Hall
12/8/2014	9885	STANSBURY PARK IMPROVEMENT D	23003	(COMPLETED) Benson Mill Crossing Phase 8 (45 lots) - after-the-fact PA and OP	Hall
12/3/2014	9875	BEAR VALLEY RV AND CAMPGROUN	09099	New public water system	Wright
12/3/2014	9876	BEAR VALLEY RV AND CAMPGROUN	09099	Bear Valley RV Well (WS001)	Wright
12/2/2014	9874	CROYDON PIPELINE CORPORATION	15001	[COMPLETED] Spring Chlorinator (TP002) approval status; Hay Hollow North Spring (WS002) UDI follow-up	Harry
12/1/2014	9871	S AND W TRAILER PARK	23044	(COMPLETED) Exception to Storage req't & wholesale connection from Oquirrh Mountain Water Company (WS003 from System	Hall
12/1/2014	9877	TAYLOR-WEST WEBER WID	29019	Winslow Farr Jr Farm Sub. (74 lots) - waiver req. per R309-500-6(3)(b) - 4200 ft of 10-in, 1800 ft of 8-in, 7 fire hydrants (NEEDS	Johnson
11/26/2014	9872	HYRUM CITY	03008	Mt. Sterling Farms Phase 1 - water lines for 95 lots including a PRV station	Lunstad
11/26/2014	9873	LEHI CITY	25015	(COMPLETED) Exception to R309-550-7, min. water and sewer sep. (McDonald's parcel)	North
11/25/2014	9866	SOUTH SALT LAKE CITY WATER SYS	18032	(COMPLETE) 300 East Well (WS011) maintenance - chemical treatment	Harry
11/25/2014	9867	VA MEDICAL CENTER SLC	18173	(COMPLETED) New PWS review & tech assistance on treatment and cross connection	North
11/19/2014	9863	PINE LAKE CAMPGROUND	09017	(COMPLETED) 8,000 gal. steel storage tank (ST002) to replace 3,000 gal. fiberglass tank (ST001)	Wright
11/19/2014	9864	OQUIRRH MOUNTAIN WATER CO	23076	(COMPLETED) consecutive connection to S&W Trailer Park PWS (System #23044) Phase I, 12-in water main, PRV and meter sta.	Hall
11/14/2014	9861	ROCKY RIDGE TOWN WATER SYSTE	12019	(COMPLETE) Quality Craft pipeline replacement, fire hydrant	Chartier
11/13/2014	9860	SARATOGA SPRINGS CITY	25138	1,800 ft of 18-in DIP water line, booster pump sta. (PF005?), and canal crossing	Kobzeff
11/10/2014	9854	UKON WATER COMPANY	02014	(COMPLETED) Exception Request - Ukon Spring Fencing WS004	Hart
11/10/2014	9855	UKON WATER COMPANY	02014	(COMPLETED) Exception Request - Check Valve in Well #1 (WS006)	Hart

<i>Received</i>	<i>File No.</i>	<i>System Name</i>	<i>System No.</i>	<i>Project Description</i>	<i>DDW Engineer</i>
11/6/2014	9858	MANTUA VALLEY CAMP	02075	Iron and manganese removal system (TP001)	North
11/5/2014	9850	SPRINGVILLE CITY	25005	16-inch Waterline - Tank to 1700 East	North
11/5/2014	9851	DAMMERON VALLEY WATER WORK	27030	Pinion Hills Water Line Extension along Sand Cove Road - 10,500 ft of 8-in water line	Wright
11/5/2014	9852	ELK MEADOWS SSD	01002	Aspen Crest Subdivision - water lines, prv's, and hydrants for 23 lots	Wright
11/5/2014	9853	TAYLORSVILLE-BENNION ID	18021	[COMPLETED] Atherton East Well (WS023) - clean and rehab.; exception to R309-515-6(6)(a)	Harry
11/5/2014	9857	CRESCENT REGIONAL CAMP	25172	(COMPLETED) Chlorinator (TP001)	North
11/4/2014	9849	MIA SHALOM RECREATION CAMP	20039	Chlorinator (TP001)	Chartier
11/4/2014	9900	LAYTON CITY WATER SYSTEM	06018	[Completed] Hillfield Storage Reservoir No. 1 - exception to R309-545-13(5) overflow connection to sanitary sewer	
11/3/2014	9844	DEER HAVEN CAMPGROUND	11019	10,000 Gallon Water Storage Tank (ST002)	Wright
11/3/2014	9845	JORDANELLE SSD	26086	(COMPLETED) Plan Submittal Waiver Eligibility Request per R309-500-6(3)(b)	North
11/3/2014	9846	TWIN CREEKS SSD	26080	(COMPLETED) Plan Submittal Waiver Eligibility Request per R309-500-6(3)(b)	North
11/3/2014	9847	NORTH VILLAGE SSD	26096	(COMPLETED) Plan Submittal Waiver Eligibility Request per R309-500-6(3)(b)	North